



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEX EPS 23.0039X** Page 1 of 3 Certificate history:
Status: **Current** Issue No: 0
Date of Issue: 2023-11-28
Applicant: **i.safe Mobile GmbH**
i_Park Tauberfranken 10
97922 Lauda-Koenigshofen
Germany
Equipment: **IS-VS1A.1 intrinsically safe, robust inspection system for leakage detection**
Optional accessory:
Type of Protection: **Intrinsic safety "i"**
Marking: **Ex ib IIC T4 Gb**
Ex ib IIIC T135°C Db

Approved for issue on behalf of the IECEx
Certification Body:

Position:

Signature:
(for printed version)

Date:
(for printed version)



1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

Bureau Veritas Consumer Products Services Germany GmbH
Businesspark A96
86842 Türkheim
Germany





IECEX Certificate of Conformity

Certificate No.: **IECEX EPS 23.0039X**

Page 2 of 3

Date of issue: 2023-11-28

Issue No: 0

Manufacturer: **i.safe Mobile GmbH**
i_Park Tauberfranken 10
97922 Lauda-Koenigshofen
Germany

Manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-11:2023 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:7.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

DE/EPS/ExTR23.0045/00

Quality Assessment Report:

DE/EPS/QAR12.0003/15



IECEX Certificate of Conformity

Certificate No.: **IECEX EPS 23.0039X**

Page 3 of 3

Date of issue: 2023-11-28

Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The IS-VS1A.1 was developed for use in hazardous areas of zones 1 and 21. In combination with mobile communication devices, the inspection system enables valve leaks to be recorded and displayed quickly and easily.

Electrical data:

The power supply and the connection of the data interface of the IS-VS1A.1 takes place via the ISM interface of the compatible communication devices. The IS-VS1A.1 is approved in combination with the IS540.1 or other mobile devices that correspond to the connection parameters according to document 1070AD04.

Other approved accessories:

- Sensor IS-SU150F1.1
- Sensor IS-SU150F2.1
- Sensor IS-SU030F2.1
- Sensor cable IS-SC120BB1.1
- Waveguide IS-WGxx.1
- Waveguide Lock IS-WGLF1.1

SPECIFIC CONDITIONS OF USE: YES as shown below:

The 16-pin connector of the IS-VS1A.1 may only be installed or removed from the ISM interface outside of potentially explosive areas.

The device must be protected against high mechanical hazards, strong UV radiation and electrostatically charging processes.

Inside explosion hazardous areas Sensors, Waveguide and Waveguide Lock must always be earthed. This could be achieved by the user or other from i.safe MOBILE GmbH approved accessory. Also placing on an earthed conductive surface is possible.

The permissible ambient temperature range is -20 °C to +55 °C.